

## **Addendum #1: Q&A Published 10/17/2022**

This information is related to the City of White's Request for Qualifications for Architectural/Engineering Services for the GEFA PFAS Remediation Grant Application  
RFP ISSUE DATE: September 20, 2022  
RFP DUE: October 25, 2022 BY 4:00 P.M.

### Questions from Bidders:

Q. Is the City of White obligated to distribute water/sewer services to the entire water service area?  
a. No.

Q. Is the two-step selection process procurement method required due to potential grant funding? Does this same selection process apply to a GEFA loan bid?  
a. Yes, the two-step selection process for Architectural/Engineering Services (A/E) is required by GEFA if the anticipated project cost is more than \$3,000,000 and A/E services are more than \$100,000. This same criteria applies to GEFA loan applications.

Q. How many functioning wells does the City of White currently have?  
a. Three. These are wells #1, #2 and #5.

Q. Does well #5 have a filter? It seems to be a "problem well"/get "muddied up" faster than the other wells.  
a. Yes, well #5 has a filter.

Q. What is the status of wells #3 and #4 and where are they located?  
a. These were most likely test wells and have been abandoned.

Q. Is there a well #6?  
a. Well #6 was drilled but is not currently in use. The developer noticed a sinkhole nearby and abandoned the project site. The site was also near a creek, on land with vertical seams, that provided plenty of water but became muddy quickly.

### **Closing location:**

Attn: Kathy Gill, Certified County Clerk  
RE: City of White GEFA Grant RFQ2022  
Bartow County Commissioner's Office  
135 W. Cherokee Avenue, Suite 251  
Cartersville, GA 30120

### **Contact person:**

Claire Mulkey  
Phone: 770-607-6202  
[mulkeyc@bartowcountyga.gov](mailto:mulkeyc@bartowcountyga.gov)